

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:106 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model 505G, M2M-CMM, 2M-CMM, and ED2M-CMM conversion module. Unit is intended to be used with listee's smoke detectors (CSFM Listing No. 7272-1591:105) and a separately listed compatible fire alarm control panels to provide interface between conventional two-wire smoke detectors and an initiating circuit intended for conventional 4-wire smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 - 33 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessory for use with separately listed electrically compatible fire alarm control units.

XLF: 7300-0447:139

NOTE: Formerly 7300-1388:229

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager